



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th & 5th Floor, ISBT Building Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)

## CONSENT ORDER

Certificate No. :G-24499

<b>Name of the unit</b>	:	Expansion of Sri Balaji Action Medical Institute A Unit of Lala Munni Lal Mange Ram Charitable Trust
<b>Address</b>	:	FC 34 A4 Paschim Vihar, New Delhi 110063, Health Care Facility, Delhi - 110063
<b>Consent Order No</b>	:	DPCC/CMC/2022/7817249
<b>Date of issue</b>	:	22/06/2022
<b>Product/Activity</b>	:	Health Care Establishments having bed strength above 50 beds and connected or not connected to Sewer and with boiler
<b>Manufacturing Activities</b>	:	N.A.
<b>Category Name</b>	:	[RED]
<b>Prout Capacity</b>	:	500 Numbers/Day

This Consent to **Establish** is hereby granted under section 21 of the Air (Prevention & Control of Pollution) Act, 1981 and under section 25/26 of the Water (Prevention & Control of Pollution) Act, 1974 under **RED** Category. This consent is subjected to terms and conditions specified overleaf. **This is being issued with reference to your application id 7817249 valid from 27/05/2022 to 26/05/2025.**

Senior Environmental Engineer

## Terms and Conditions

1. The Consentee shall meet the effluent standards i.e. pH = 6.5-9, Total Suspended Solids (TSS) = 100, Biochemical Oxygen Demand (3 days at 27 degree Cent.) = 30, COD = 250, Oil and Grease = 10, Bio-assay Test (Present survival of fish after 96 hours in 100% effluent) = 90-100 %. All effluent parameters are in mg/l except pH value & Bioassay test value.
2. The Consent is activity specific and based on the information provided in the consent application along with the subsequent documents/ information submitted to Delhi Pollution Control Committee (DPCC). The Consentee shall apply for fresh consent in case of any change in the activity/ manufacturing process.
3. The Consentee shall display the Name of the unit along with its Address, name of the Proprietor /Directors/ Partners etc, Contact Phone No(s) and its Activities/ Processes/ Products on a Display Board to be placed / fixed at the main gate of the unit.
4. The Consentee/ unit shall have/ take separate Electricity/ Power connection in its name and shall have/ install separate meter in this regard.
5. The Consentee shall provide and maintain a separate drainage system for collection of trade and sewage effluents. Terminal manholes shall be provided at the end of the collection system and shall be connected to the conveyance system/ sewerage system of the area leading to the Common Effluent Treatment Plant of the Industrial Area/ Sewage Treatment Plant of the catchment area.
6. The Consentee shall obtain permission from Delhi Jal Board for ground water extraction, if any, as per the various orders/ Notification of Govt. of NCT of Delhi. The Consentee shall not extract the groundwater without obtaining prior permission in this regard from DJB/ CGWA. The Consentee shall ensure that there is no bore well in the premises and if exist, the same shall be closed/ sealed with immediate effect till permission received from DJB/ CGWA.
7. The Consentee shall ensure proper channelization/ control system for fugitive emissions generated from the various activities/ processes of the unit and maintain good housekeeping practices so as to maintain a clean & safe environment in and around the premises of the unit.
8. The Consentee shall comply with the noise standards laid down vide Gazette Notification of Ministry of Environment and Forest (MoEF), Government of India Dated 17.05.2002 & 12.07.2004, as amended to date, for the Diesel Generator Set(s) and shall also comply with the Emission Standards prescribed for Diesel Engines [(Engine rating more than 0.8 MW) for Power Plant, Generator Set applications and other requirements], if any, as per the Gazette Notification of MoEF, Dated 09.07.2002, as amended to date. Stack Height for sets (Engine rating more than 0.8 MW) commissioned after 01.07.2003 shall be maximum of following:
  - a). Minimum 6 metre above the building where generator set is installed
  - b). 30 metre
  - c).  $14Q^{0.3}$  (Q- Total SO<sub>2</sub> emission from the plant in kg/hr) and for other DG Set(s) (upto 0.8 MW) stack height shall be as per the following formula,  $H = h + 0.2(KVA)^{0.5}$  (H- Total Height of stack in metre, h = Height of the building in metres where the Generator Set is installed, KVA - Total Generator capacity of the set in KVA).
9. The Consentee shall comply with the provisions of the Hazardous and Other Wastes(Management and Transboundary Movement) Rules, 2016, as amended to date, the Batteries (Management and Handling) Rules, 2001 as amended to date, Solid Waste Management Rules, 2016 and E-Waste (Management) Rules, 2016, the Manufacture, Storage and Import of Hazardous Chemicals Rules, 1989, as amended to date, wherever applicable. All such wastes generated from the unit will be managed and handled as per the provisions of the said Rules and will be disposed off only through the Recycler/ Preprocessors/ Authorised Agencies for such wastes, authorised by MoEF/ Central Pollution Control Board/ State Pollution Control Board/ Committee/ DPCC as per details available on their websites.
10. The Consentee shall comply with the provisions of Solid Waste Management Rules, 2016 as amended to date.

11. The Consentee shall comply with the provisions of the Biomedical Waste Management Rules, 2016, as amended to date.
12. The Consentee shall comply with the provisions of the Plastic Waste Management Rules, 2016, as amended to date, if applicable.
13. The Consentee shall comply the other prescribed standards of Effluent/ Emissions as prescribed and as applicable under the provisions of the Environment (Protection) Act, 1986, as amended to date and the various Rules made there under including the Noise Pollution (Regulation and Control) Rules, 2000 as amended to date.
14. The Consentee shall promote the use of LED and recovery of mercury from CFL Lamps and should create a system of replacing old bulbs for new to enable recovery of mercury after the bulbs are fused.
15. Total water demand of the project is expected to be approx. 455KLD ( Fresh water demand is 133 KLD will be met through 117.85 KLD from DJB & 15.15 KLD from Tanker Supply). Trade Effluent generated from process, washings, cooling water blowdown, boiler blowdown, DM Plant/ Softening Plant Washings, other activity i.e. (1 KLD) will be treated in ETP of 3 KLD. Expected Domestic wastewater generation will be 282 KLD and will be treated in STP of 600 KLD to meet prescribed standard as given the consent order before operation of the project.
16. Sludge from Effluent Treatment Plant shall be given to common bio-medical waste treatment facility for incineration or to hazardous waste treatment, storage and disposal facility for disposal.
17. The zero wastewater discharge condition to be achieved with installation of onsite Sewage Treatment Plant. Trade effluent shall conform to the norms and standards prescribed by Delhi Pollution Control Committee. The STP should be certified by an independent expert and a report in this regard should be submitted to Delhi Pollution Control Committee before the project is commissioned for operation. Necessary measures should be made to mitigate the odour problem from STP.
18. The treated wastewater of STP shall be recycled and reused for horticulture/ landscaping/ cooling/ flushing purposes to reduce the demand of fresh water as committed.
19. The Project Proponent shall provide electromagnetic flow meter at the inlet and outlet of the water supply, inlet and outlet of the STP and any pipeline to be used for re-using the treated wastewater back into the system for cooling, flushing and for horticulture purpose/ green etc. and shall maintain a record of readings of each such meter on daily basis.
20. The quantity of fresh water usage and water recycling shall be measured and recorded to monitor the water balance as projected by the Project Proponent. The record shall be submitted to the Delhi Pollution Control Committee on six monthly basis. The water requirement shall be met from the sources as per the details mentioned in the Environmental Clearance.
21. Capacity of the Diesel Generator Set (s) installed in the HCF are 3\*750 KVA. The Consentee shall properly maintain the Acoustic Enclosure/ Acoustic Treated room for DG Set(s) in good condition and maintain the adequate stack height for DG Set(s) to meet the prescribed standards/ norms as mentioned above. The Consentee shall not operate the DG Set(s) till compliance of the prescribed norms/standards for DG Sets.
22. The Consentee shall comply with the applicable provisions/ Directions given vide Gazette Notification of Department of Environment, Govt. of NCT of Delhi, dated 23.10.2012 including the directions that no person shall manufacture, import, store, sell or transport any kind of plastic carry bags (including that of PolyPropylene, Non-woven fabric type carry bags) in the whole of National Capital Territory of Delhi if applicable.
23. The Consentee shall provide widespread Green Cover and the use of Fly Ash as per Fly Ash notification dated 14.09.1999 shall be mandatory.
24. Project Proponent will ensure use of Ozone Depletion Substances (ODS) free appliances so that no toxic gases in air conditioning/ refrigeration/ fire extinguishers are created.
25. During the Construction Phase for Control of dust pollution all precautionary measure should be ensured

incompliance of Hon'ble National Green Tribunal order dated 04.12.2014 in the matter of Vardhaman Kaushik Vs. Union of India & Ors. and Sanjay Kulshrestha Vs. Union of India & Ors. and as notified by MoEF&CC, GOI vide Notification No. G.S.R. 94(E) dated 25.01.2018. Consignee shall use Anti-Smog Gun(s) compulsorily for undertaking construction & demolition activity including excavation, material handling and other dust generating activities for compliance of Hon'ble Supreme Court orders dated 13.01.2020 in WPC No. 13029/1985 titled M.C. Mehta Vs. Union of India & Ors.

26. It will be the responsibility of the Project Proponent to obtain prior clearances/ approval and ensure compliances under all other relevant Acts/ Rules/ Regulations/ Guidelines/ Instructions/ Court Orders/ Tribunal Orders as applicable to this project before starting of the project.

27. The Consentee shall not carry out any activity falling under the Prohibited/ Negative list of Industries (Annexure III of MPD -2021) which are prohibited in National Capital Territory of Delhi, as per Master Plan of Delhi.

28. Unit shall implement the environmental safeguards as per stipulations in Environmental Clearance issued by SEIAA Delhi and shall submit a half yearly compliance report in respect of terms and conditions of Environmental Clearance to Regional Office of MoEF&CC and simultaneously to DPCC on the prescribed date.

29. The Consentee shall submit an application for extension of the Consent to Establish/ Consent to Operate under Water and Air Acts & Authorization under BMWM Rules, 2016 one month in advance of the expiry date of this Consent Order/ date of start of operation of the HCF.

30. This consent is being granted focusing only on the Water Act 1974/ Air Act 1981. The project will be regulated by the concerned local Civic Authorities under the provisions of the relevant provisions of the extant MPD-2021, Building Control Regulations and Safety Regulations. The investment made in the project, if any, based on Consent so granted, in anticipation of the clearance from other statutory authorities shall be entirely at the cost and risk of the project proponent, DPCC shall not be responsible in this regard in any manner.

31. The Consentee is allowed to run the pollution control devices and collect and test the data. The trial for these aforesaid purposes is permitted within the period of maximum three months from the date of completion. The Consentee shall give prior intimation to DPCC, of the dates on which trial would start and end. Thereafter Project Proponent shall apply for Consent to Operate along with requisite details and test reports to DPCC.

32. The Consentee shall abide by the Guidelines on Environmental Management of Construction and Demolition (C&D) Waste and Guidelines on Dust Mitigation Measure in Handling Construction Material and C&D waste developed and published by CPCB available at [www.cpcb.nic.in](http://www.cpcb.nic.in)

33. The Consentee shall display the enclosed template of Notice for Construction and Demolition Waste Management at the site.

34. The Consentee shall ensure the compliance of policy to be followed regarding operation of Ready Mix Concrete Plants (RMC Plants) issued vide office order No. DPCC/CMC I/RMC/2017/2596 to 2614 dated 27.12.2017 (available at DPCC website).

35. In the event of any information furnished by the Consentee found to be false OR in case of failure to comply with any of the above mentioned consent conditions, consent granted through this Consent Order shall be deemed to be revoked without any notice and necessary action as per law shall be taken, which may include closure of the unit and prosecution for wrong declaration.

36. Notwithstanding anything contained in this Consent Order. Delhi Pollution Control Committee, reserves its right to review any/ or all the conditions imposed herein above and to make such variations as deemed fit for the purpose of enforcement of the Air (Prevention and Control of Pollution) Act, 1981, as amended to date and the Water (Prevention and Control of Pollution) Act, 1974, as amended to date.

37. The Consent granted to the Consentee is to ensure control of pollution from the premises of the unit in accordance with various Pollution Control Laws and in no way confers the right to the Consentee / unit to

exist in violation of other laws and statutory provisions including the Master Plan of Delhi.

38. The Consentee shall ensure the safeguards as envisaged in Environmental Clearance issued to Shri Rajkumar Gupta, Trustee M/s Lala Munni Lal Mange Ram Charitable Trust vide file no. 21-7/2019-IA-III DATED 18.10.2019 including the dust control measures during the construction stage.

39. This issue in view of the Office Order dated 12.04.2016 regarding processing of the Consent to Establish cases.

Template for displaying notice w.r.t. Condition No. 33 to be displayed on board of size 6 feet X 4 feet.

Background color - Yellow, Letters - Black

#### NOTICE

(Construction and demolition waste management rule 2016)

The construction/Demolition site is authorized by... Vide file no... Dated.....

1. Name and Address with contact number of contractor/developer

2. Address of the site

3. Area/length

4. Date of initiation of the project (dd/mm/yy)

5. Scheduled completion date of the project (dd/mm/yy)

6. Details date of completion/disposal/clearing of the site (dd/mm/yy)

7. Estimated waste (TPD)

8. Total estimated waste (MT) for the entire project

9. Nature of waste (concrete/iron/plastic/soil) (TPD)

10. Material Generated Recycled Reused Disposed

Sand -----

Concrete -----

11. Identified waste disposal site

12. Mode of utilization of waste (reuse/recycle/convert to construction material)

13. Mode of disposal

14. Mode of handling and transportation (manual/mechanical/pneumatic)(by road/rail)

15. Dust mitigation measures at the site (water sprinkling/curtain/barrister)

16. Reason of delay in disposing waste (in any)

17. Accidents reported (in any)

Name of Agency Owner

Telephone number